



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

D'ARCY DIXON PIGNANELLI

Executive Director

Division of Purchasing and General Services

DOUGLAS G. RICHINS, C.P.M.

Division Director

January 27, 2006

*****ADDENDUM #1*****

SOLICITATION: DG6524
DUE DATE: 02/06/06
TIME: 5:00 P.M.

DESCRIPTION: Building for Backup Power Generator.

Please note the following changes:

1. On page 1 of the Communications Building Bid Specifications Under SIZE please change specifications to read: the Shelter shall be 12' wide O.D. X 10' long O.D. X **8'** high I.D. (instead of 9' high I.D. as previously indicated).
2. On page 2 of the Bid Construction Details under 1. SKID ASSEMBLY on the last sentence please change specifications to read: The complete skid assembly shall be constructed of **steel with rust preventative paint** and secured to the finished sub-floor with high strength 3" lag bolts. (instead of galvanized steel).
3. **Due date and time remain the same February 06, 2006 at 5:00 P.M.**

*****END OF ADDENDUM*****

To acknowledge receipt of addendum, include a copy of this addendum with the proposal submittal or give written acknowledgment with the proposal. It shall be the responsibility of the respondent to appropriately disseminate this information to all concerned prior to the assigned due date and time.

Name

Signature

Company

Date